



OCCUPATIONAL SAFETY AND HEALTH REVIEW COMMISSIONAL SAFETY & HEALTH

RALEIGH, NORTH CAROLINA

COMMISSIONER OF LABOR FOR)	DOCKET NO: 2012 - 5274
THE STATE OF NORTH CAROLINA)	
)	INSPECTION
)	NO: 315960914
Complainant,)	
)	CSHO ID: N8928
v.)	
)	
CARMEL CONTRACTORS, INC)	ORDER
and its successors)	
)	
Respondent.)	

THIS CAUSE coming on for Hearing on January 8, 2013 at the Lee House, 2nd Floor Hearing Room, 422 North Blount Street, Raleigh, North Carolina at 10:00 a.m. Jason R. Rosser, Assistant Attorney General appeared as counsel for the Complainant, the Commissioner of Labor, and Greg C Ahlum, appeared as counsel for the Respondent, Carmel Contractors, Inc.

FINDINGS OF FACT

Based on the stipulations at the time of the Hearing and the record the Undersigned makes the following Findings of Fact:

- I. This Court has jurisdiction over the parties and the subject matter of this Hearing.
- II. Respondent is a North Carolina corporation, duly organized and existing under the laws of the State of North Carolina.
- III. Respondent is subject to the jurisdiction of the Safety and Health Review Commission of North Carolina.
- IV. All notices required by the Act and by any applicable procedural and substantive rules have been given.
- V. Neither party has any procedural objection to this Hearing.
- VI. Complainant, Commissioner of Labor of the State of North Carolina, is an agency of the State of North Carolina charged with the administration and enforcement of the provisions of the Occupational Safety and Health Act of North Carolina, Article 16, Chapter 95 of the General Statutes of North Carolina (hereinafter "the Act").

A Pre-Hearing conference was held. As a result of such conference the following agreements between Complainant and Respondent were entered of record:

- * Respondent will implement a reasonable fire protection plan;
- * Respondent will train its supervisors in control decking zone construction within 60 days from the date this Order is entered;
- * For walls required to be braced under 29 CFR1926.706 the Respondent will make reasonable efforts to evacuate the control access zone on both sides of the braced wall or on the braced side of the wall where scaffold is erected on the opposite side in the following two weather conditions: a) during sustained 20 mph winds when braced masonry walls have not cured for 24 hours; and b) during sustained 35 mph winds for other braced masonry walls;
- * This will be deemed a final order with regard to any future North Carolina OSHA proceedings, but not an admission of liability in any civil actions not involving the Department of Labor of the State of North Carolina.

Further, as a result to the Pre-Hearing conference the following Motions were made:

Complainant Moved: (1) to Amend Citation 1, Item 1 because of a clerical error in the alleged violation description, thereby changing the description from "29 CFR 1926.452(h)(2)(i)" to "29 CFR 1926.451(h)(2)(i)"; and (2) to Dismiss Citation 1 Item 2a, Citation 1 Item 2b, Citation 1 Item 3, and Citation 2 Item 1.

Respondent did not object to such Motions, and Complainant's Motions are hereby GRANTED.

Respondent Moved to withdraw its Notice of Contest to Citation 1 Item 1 as Amended.

Complainant did not object to such Motion, and Respondent's Motion is hereby

GRANTED. Respondent shall make payment of the \$1,000 Penalty within 20 days from the date this Order is entered.

This the 12th day of January, 2013.

R. Joyce Garrett

Administrative Law Judge

Loyu Jam of

527412.ORD

CERTIFICATE OF SERVICE

I HEREBY CERTIFY that I have this date served a copy of the foregoing ORDER, upon:

GREG C AHLUM
JOHNSTON ALLISON & HORD PA
PO BOX 36469
CHARLOTTE NC 28236

by depositing same the United States Mail, Certified Mail, postage prepaid, at Raleigh, North Carolina, and upon:

JASON ROSSER
NC DEPARTMENT OF JUSTICE
LABOR SECTION
P O BOX 629
RALEIGH NC 27602-0629

by depositing a copy of the same in the United States Mail, First Class;

NC DEPARTMENT OF LABOR LEGAL AFFAIRS DIVISION 1101 MAIL SERVICE CENTER RALEIGH NC 27699-1101

by depositing a copy of the same in the NCDOL Interoffice Mail.

 \mathcal{O}

2013.

OSCAR A. KELLER, JR

CHAIRMAN

Nancy D. Swaney

Docket and Office Administrator

NC Occupational Safety & Health Review Commission

1101 Mail Service Center Raleigh, NC 27699-1101 TEL.: (919) 733-3589

FAX: (919) 733-3020